



July 2004

Suggested Custom Control Panel Specification

The boiler electrical control panel shall be NEMA ____ rated and UL Industrial Control Panel Listed. It shall have ____ green status lights to indicate that the following conditions are “on”: _____
_____.

Separate sets of dry terminal block contacts shall close to indicate that each of the following status lights are “on” for remote communications: _____
_____.

The panel shall have ____ red fault lights to indicate that the following safety or limit controls are “off” (open switch): _____
_____.

A single set of dry terminal block contacts shall close when any fault light comes “on” for remote communications.

The panel shall include an alarm bell and pushbutton silencing switch for any fault condition that requires manual reset.

The panel shall include an enable/disable (start-stop) relay with 24 volt (120V optional) coil, if required.

All status and fault light shall be visible from the front of water boilers and from the side of steam boilers.

The flame safeguard control shall be mounted on the outside top of the panel (unless otherwise specified & ordered to be inside the panel).

Rite ENGINEERING & MANUFACTURING CORPORATION

9441 Washburn Road Downey, California 90242

Phone (562) 862-2135 • Fax (562) 861-9821 • www.riteboiler.com